

# Certificate of Conformity

**Bachmann electronic GmbH**  
**Kreuzäckweg 33**  
**AT-6800 Feldkirch**  
**Austria**

|                                  |  |  |
|----------------------------------|--|--|
| Type of equipment                | Protective device  |  |
| Product Name                     | Product family GMP232/x2. GMP232/x2 CC<br>GMP232/12 GMP232/12 cc / GMP232/22 GMP232/22 cc GMP232/32 GMP232/32 cc<br>GMP232/42 GMP232/42 cc GMP232/52 GMP232/52 cc  |  |
| Technical data                   | Nominal measuring voltage: $U_r = 120 \text{ V}, 690 \text{ V}, 1000 \text{ V}$<br>Nominal measuring current: $I_r = 1 \text{ A or } 5 \text{ A}$<br>Nominal measuring frequency: $f = 35 - 65 \text{ at } 50 \text{ Hz}$<br>$45 - 75 \text{ at } 60 \text{ Hz}$<br>Power supply voltage: $U_{DC} = 18 - 34\text{V, typ. } 24\text{V}$ |  |
| Certification scheme             | P30VA01<br>Rev. 09/11.24   | TÜV NORD- Certification Process for Grid Integration Certification   |
| Gridcodes                        | PTPIREE v1.3<br>01.10.2024   | Warunki i procedury wykorzystania certyfikatów w procesie przyłączenia modułów wytwarzania energii do sieci elektroenergetycznych  |
|                                  | PN-EN 50549-1:<br>2019-02<br>/Ap1:2020-08  | Wymagania dla instalacji generacyjnych przeznaczonych do równoległego przyłączenia do publicznych sieci dystrybucyjnych<br>Część 1: Przyłączanie do sieci dystrybucyjnej nN Instalacje generacyjne aż do typu B i włącznie z nim |
|                                  | PN-EN 50549-2:<br>2019-02<br>/Ap1:2020-08  | Wymagania dla instalacji generacyjnych przeznaczonych do równoległego przyłączenia do publicznych sieci dystrybucyjnych<br>Część 2: Przyłączanie do sieci dystrybucyjnej SN Instalacje generacyjne aż do typu B i włącznie z nim |
| Scope of assessment              |  |  |
| PN-EN 50549-1<br>/ PN-EN 50549-2 | Chapter 4.9<br>Chapter 4.10<br>Chapter 4.13  | Interface protection<br>Connection and starting to generate electrical power<br>Requirements regarding single fault tolerance of interface protection system and interface switch (only PN-EN 50549-1)                           |
| PTPIREE v1.3                     | Chapter 3  | Sposób sprawdzenia zdolności   |

The components comply with the requirements of the Gridcodes specified above, with restrictions. For further details and technical specifications, please refer to Annex 1 (consist of 3 pages).

Certificate Registration No. 44 876 13137905      valid from 2026-05-05  
Evaluation Report No. 3542 2981                      valid till 2031-05-04

Essen, 2026-05-05  
Rev. 1.0

Certification body of TÜV NORD CERT GmbH

TÜV NORD CERT GmbH  
Am TÜV 1, 45307 Essen  
Germany  
www.tuev-nord-cert.com



Additional standards/  
guidelines

EN 50549-10  
2022

Requirements for generating plants to be connected in parallel  
with distribution networks: - Part 10: Tests for conformity  
assessment of generating units

Bank Nastaw  
dla Polski -  
projekt 2024  
26.03.2024

Zbiór nastaw i kryteriów zabezpieczeniowych oraz parametrów  
konfiguracyjnych charakterystyk regulacyjnych dla MWE typu A i B

Essen, 2026-05-05  
Rev. 1.0

TÜV NORD CERT GmbH  
Am TÜV 1, 45307 Essen  
Germany  
[www.tuev-nord-cert.com](http://www.tuev-nord-cert.com)

TÜV®




# ANNEX 1

for the Certificate of Conformity with the Registration No. 44 876 13137905

**Bachmann electronic GmbH**  
**Kreuzäckweg 33**  
**AT-6800 Feldkirch**  
**Austria**

## Schematic structure of Protection device



Essen, 2026-05-05  
 Rev. 1.0

TÜV NORD CERT GmbH  
 Am TÜV 1, 45307 Essen  
 Germany  
 www.tuev-nord-cert.com

TÜV®

Page 1 of 3

# ANNEX 1

for the Certificate of Conformity with the Registration No. 44 876 13137905

## Technical data of Protection device

| Designation                  | GMP232/12<br>GMP232/12<br>cc                      | GMP232/22<br>GMP232/22<br>cc | GMP232/32<br>GMP232/32<br>cc | GMP232/42<br>GMP232/42<br>cc | GMP232/52<br>GMP232/52<br>cc |
|------------------------------|---|------------------------------|------------------------------|------------------------------|------------------------------|
| Auxiliary power supply       | 18 – 34 V <sub>DC</sub> , typ. 24 V <sub>DC</sub> |                              |                              |                              |                              |
| Power consumption            | max. 1,3W   |                              |                              |                              |                              |
| Nominal measuring voltage    | 120 V <sub>RMS</sub>                              | 690 V <sub>RMS</sub>         | 120 V <sub>RMS</sub>         | 690 V <sub>RMS</sub>         | 1000 V <sub>RMS</sub>        |
| Nominal measuring current    | 1 A <sub>RMS</sub>                                |                              | 5 A <sub>RMS</sub>           |                              | 1 A <sub>RMS</sub>           |
| Nominal measuring frequency  | 35 – 65 Hz at 50 Hz<br>45 – 75 Hz at 60 Hz        |                              |                              |                              |                              |
| Burden (current measurement) | 10 mVA  |                              | 250 mVA                      |                              | 10 mVA                       |
| Burden (voltage measurement) | >3,2 MΩ   |                              |                              |                              | >5 MΩ                        |
| Relay outputs                | 2   |                              |                              |                              |                              |
| Relay inputs                 | 0   |                              |                              |                              |                              |
| Construction revision        | 120.000 / 125.000                                 |                              |                              |                              |                              |
| Software version (SW)        | 1.xx R  |                              |                              |                              |                              |

# ANNEX 1

for the Certificate of Conformity with the Registration No. 44 876 13137905

## Remarks

### Protection against unauthorised manipulation

To protect the device configuration as well as the limit values and parameters of the protective functions against unauthorised manipulation, the corresponding security features must be activated on the control CPU. An application must be used to ensure a password structure. This is described in the user manual.

### Inputs

The protection devices of the GMP232/x2 product family have no relay inputs. The required inputs can be implemented through any digital channel of an M200 module.

### Application

An additional application is required to switch to a narrower frequency band as well as to activate an additional switch in the event of a coupling switch failure. These are described in the manufacturer's declaration and will be included in the user manual.

### Quality management system

The manufacturer has demonstrated the certification of its quality management system in accordance with ISO 9001 and will maintain this for the duration of the validity of this unit certification in accordance with a manufacturer's declaration.

## Restrictions

### Single fault safety according to PN-EN 50549-1

To ensure single fault security, two identical assemblies with identical parameterisation must be used in accordance with the manufacturer's specifications.

### Interference immunity

The external power supply is not part of the protective device and therefore not part of the assessment.

The interference immunity requirements must be covered in the external auxiliary power supply.

## Appendix to the Certificate

A1. Evaluation Report No. 3542 2981 Version 1.0

Essen, 2026-05-05

Certification body of TÜV NORD CERT GmbH

Essen, 2026-05-05  
Rev. 1.0

TÜV NORD CERT GmbH  
Am TÜV 1, 45307 Essen  
Germany  
www.tuev-nord-cert.com

TÜV®

